

Elevated Surfaces Hazard Checklist

Hazard Mitigation		Satisfactory	Needs Attention	Not Applicable	Target Date for Completion	Date Completed
1.	The open sides of an elevated work location , such as a roof on a building, are protected by guardrails .	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
2.	The open sides of an elevated work location in or on a building structure, such as balconies or porches, are protected by guardrails .	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
3.	The elevated location within a building or on a building structure that have a glazed (glass) landing, have guardrails installed .	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
4.	Runways or ramps that are considered elevated locations have guardrails installed on all unprotected sides.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
5.	Elevated platforms, runway, ramps have no less than 6.5 feet of clear headroom .	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
6.	Elevated platforms, runway, ramps need are no less than 2 feet wide .	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
7.	The ramp walking surface is roughened or is made of nonslip materials .	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
8.	The ramps that are more than 30 inches above the adjacent ground or floor have guardrails in place, which also extend from the top of the ramp to the bottom of the ramp with no gaps.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
9.	The unprotected sides of elevated work locations that are not buildings or building structures where an employee is exposed to a fall of 4 feet or more are protected with guardrails .	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
10.	Where the guardrail requirements are impracticable due to machinery requirements or work processes, an alternate means of protecting employees from falling, such as personal fall protection systems, is used.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
11.	Any opening in a wall or partition that is unprotected, through which a person might fall to a level 30 inches or more below, is guarded by a guardrail or other barrier .	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
12.	Access to every permanent elevated work location is by either fixed ladders or permanent ramps or stairways .	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
13.	A safe platform or maintenance runway is provided on every permanent elevated work location where the machinery/equipment is being operated or frequently repaired, serviced, or adjusted.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		
14.	A safe means of access (portable or fixed ladder or permanent stairway) is provided on every permanent pit, sump, or other sunken location 30 inches or more in depth in, or from which, machinery, equipment, or materials are customarily operated or frequently repaired, serviced, or adjusted.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>		

Actions Taken to Correct Items Checked as “Needs Attention”

Hazard #	
Hazard #	
Hazard #	
Hazard #	
Hazard #	

The above evaluations and/or recommendations are for general guidance only and should not be relied upon for medical advice or legal compliance purposes. They are based solely on the information provided to us and relate only to those conditions specifically discussed. We do not make any warranty, expressed or implied, that your workplace is safe or healthful or that it complies with all laws, regulations or standards.

For more information, visit: www.SafeAtWorkCA.com

Name

Date